

2020 Water Quality Report for Sanilac Township

This report covers the drinking water quality for Sanilac Township for the 2020 calendar year. This information is a snapshot of the quality of the water that we provide to you in 2020. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Your water comes from the Village of Lexington water filtration plant. The source water is the 51,737 square mile water shed basin commonly known as Lake Huron. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, water chemistry and contamination sources. The Village of Lexington and Sanilac Township water system is categorized as having a moderately high susceptibility to potential contaminant sources. A copy of the source water assessment is available at the Sanilac Township offices.


There are no significant sources of contamination in our water supply. We are making efforts to protect our sources. If you would like to know more about the report, please contact Daniel Kelly, Township Supervisor, at the Sanilac Township Hall.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's **Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the **Safe Drinking Water Hotline (800-426-4791)**
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs,

and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.



In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2020 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 — December 31, 2020. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

N/A: Not applicable ND: not detectable at testing limit ppb: parts per billion or micrograms per liter ppm: parts per million or milligrams per liter pCi/l: picocuries per liter (a measure of radioactivity).

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
<u>Inorganic Contaminants</u>							
Barium (ppm)	2000	2000	10		2020	No	Erosion of natural deposits
Selenium (ppb)	50	50	ND		2020	No	Erosion of natural deposits
Fluoride (ppm)	4	4	0.56		2020	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Sodium ¹ (ppm)	N/A	N/A	5.5		2020	No	Erosion of natural deposits.

Disinfectants & Disinfection By-Products

TTHM - Total Trihalomethanes (ppb)	80	N/A	50	42-58	2020	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	26	16-36	2020	No	Byproduct of drinking water disinfection
Chlorine2 (ppm)	4	4	0.66	.04-1.95	2020	No	Water additive used to control microbes

Radioactive Contaminants

Gross Alpha	15		<2.6		2016	No	Decay of natural and manmade deposits
Combined radium (pCi/L)	5		0.78		2016	No	Decay of natural and manmade deposits

Microbiological Contaminants

Total Coliform (Total number or % of positive samples/month)	TT	N/A	0	N/A	2020	No	Naturally present in the environment.
E. coli in the distribution system (Positive samples)	See Ecoli ³ note below	0	0	N/A	2020	No	Human and animal fecal waste.

<u>Inorganic Contaminant Subject to AL</u>	<u>AL</u>	<u>MCLG</u>	<u>Your Water⁴</u>	<u>Range</u>	<u># Of Samples Above AL</u>	<u>Does System Exceed AL? Yes/No</u>	<u>Typical Source of Contaminant</u>
Lead (ppb) <i>Sampled 2020</i>	15	0	2.0	0 - 3	0	No	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm) <i>Sampled 2020</i>	1.3	1.3	0.4	0 - .44	0	No	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

- Sodium is not a regulated contaminant.
- The chlorine "Level Detected" was calculated using a running annual average.
- E. coli MCL violation occurs if: (1) routine and repeat samples total coliform-positive and either is E coli-positive, or (2) supply fails to take all required repeat samples following E. coli-positive routine sample, or (3) supply fails to analyze total coliform-positive repeat sample for E. coli.
- 90 percent of the samples collected were at or below the level reported for our water.

Information about lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Sanilac Township is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

[Lead] Infants and children who drink water containing lead could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

[Copper] Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's disease should consult their personal doctor.

Service Lines: Active Service Lines: 303

Lead Service Lines: 0

Unknown Service Lines: 0

We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at Sanilac Township Hall and on the township's website (Sanilactownship.org). This report will not be sent to you.

We invite public participation in decisions that affect drinking water quality. The Sanilac Township board meetings are the first and third Wednesday of every month. For more information about your water, or the contents of this report, contact the Sanilac township hall. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for Sanilac Township

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During October 1 to October 31, 2020, we did not monitor or test for total coliform bacteria and, therefore, cannot be sure of the quality of your drinking water during that time.

What should I do?

There is nothing you need to do at this time. This is not an emergency. You do not need to boil water or use an alternative source of water at this time. Even though this is not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation. The table below lists the contaminant we did not properly test for, how often we are supposed to sample for this contaminant, how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date we collected follow-up samples.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	Date additional sample was taken
Total Coliform Bacteria	1 sample per month	0	October 1, 2020 to October 31, 2020	November 3, 2020

What happened? What is being done?

We inadvertently missed taking a sample within this required sampling period. We are making every effort to ensure this does not happen again. We were out of compliance November 1, 2020 and we returned to compliance on November 3, 2020.

For more information, please contact Township Supervisor-Daniel Kelly 810-622-8178 or System Water Operator Michael Bender 810-359-5901. This notice is being sent to you by Sanilac Township.